

MEGHALAYA CEMENTS LIMITED

CIN: U26942ML2003PLC007125

DECEMBER – 2016

STACK EMISSION MONITORING RESULTS (Average Values)

Sl.No.	Stack Attached To	Particulate Matter(mg/Nm ³)
1	Primary Crusher	0.00
2	Secondary crusher	0.00
3	Coal Mill 1	0.00
4	Coal Mill 2	0.00
5	RABH 1	0.00
6	RABH 2	0.00
7	ESP 1	0.00
8	ESP 2	0.00
9	Packing House	40.60
10	Cement Mill	41.90

AMBIENT AIR QUALITY MONITORING RESULTS (Average Values)

Stations ↓ Parameters →	Respirable Suspended Particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
	PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station # 1 (Near DG Set Area)	62.86	37.22	16.10	29.60
Station # 2 (Near Guest house)	50.18	29.56	ND	16.20
Station # 3 (Near Stone Crusher Area)	53.67	32.68	12.20	33.40

N.D – Not Detected