

MEGHALAYA CEMENTS LIMITED



CIN: U26942ML2003PLC007125

JULY – 2017

STACK EMISSION MONITORING RESULTS (Average Values)

Sl.No.	Stack Attached To	Particulate Matter(mg/Nm ³)
1	Primary Crusher	27.88
2	Secondary crusher	28.77
3	Coal Mill 1	27.79
4	Coal Mill 2	26.97
5	RABH 1	21.80
6	RABH 2	26.20
7	ESP 1	29.10
8	ESP 2	29.40
9	Packing House	28.16
10	Cement Mill	29.72
11	CPP	42.80

AMBIENT AIR QUALITY MONITORING RESULTS (Average Values)

Stations  Parameters 	Respirable Suspended Particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
	PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station # 1 (Near DG Set Area)	86.42	40.72	8.10	16.40
Station # 2 (Near Guest house)	52.85	39.13	ND	ND
Station # 3 (Near Stone Crusher Area)	65.35	39.94	11.60	24.40

N.D – Not Detected