

# MEGHALAYA CEMENTS LIMITED

CIN: U26942ML2003PLC007125

**JUNE – 2015**

## STACK EMISSION MONITORING RESULTS (Average Values)

Sl.No.	Stack Attached To	Particulate Matter(mg/Nm <sup>3</sup> )
1	Primary Crusher	37.90
2	Secondary crusher	39.22
3	Coal Mill 1	26.30
4	Coal Mill 2	32.10
5	RABH 1	26.13
6	RABH 2	33.20
7	ESP 1	35.70
8	ESP 2	27.90
9	Packing House	26.70
10	Cement Mill	41.80

## AMBIENT AIR QUALITY MONITORING RESULTS (Average Values)

Stations ↓ Parameters →	Respirable Suspended Particulate Matter (µg/m <sup>3</sup> )		Gaseous Emission (µg/m <sup>3</sup> )	
	PM <sub>10</sub>	PM <sub>2.5</sub>	SO <sub>2</sub>	NO <sub>2</sub>
Station # 1 (Near DG Set Area)	46.81	18.12	6.36	16.56
Station # 2 (Near Guest house)	29.35	12.50	N.D.	10.02
Station # 3 (Near Stone Crusher Area)	66.33	33.73	9.10	11.79

N.D – Not Detected